



October 1, 2016

Alex Sewell
Town Manager
Town of Wadesboro
124 E. Wade Street
Wadesboro, NC

Transmitted via electronic mail to wadesboromanager@windstream.net

Re: 125 S. Washington Street Asbestos Sampling

Mr. Sewell:

On September 28, 2016, I conducted additional asbestos sampling at the property referenced above. I am a NC licensed Asbestos Inspector (#110147). This letter is meant as meant to be an addition to report we produced for CES Group on January 20, 2009, which documented asbestos sampling conducted on January 14, 2009 by Chris Burnett. At the time of the initial inspection, counters remained in place on the first floor of the building that covered the 9" x 9" vinyl floor tiles that the demolition contractor expressed concern over.

Laboratory analysis revealed that the red/brown 9" x 9" vinyl floor tiles and the underlying black mastic were both Asbestos Containing Materials (ACM). There was approximately 20 square feet of vinyl floor tile in various places throughout the first floor. The black mastic could also be found throughout the front part of the first floor, both exposed and beneath the carpet. There was approximately 1,000 square feet of black mastic. There was no asbestos detected in the black carpet mastic on the top of the floor tile.

A photograph of the ACM material, copies of my and the laboratory's licenses, and a copy of the laboratory analysis can be found below.

If you have any questions, please let us know.

Sincerely,

Kathryn O. Hubicki
President

PHOTOGRAPH



ACM Vinyl Floor Tile & Black Mastic

LABORATORY ANALYSIS



September 30, 2016

Get The Lead Out, LLC
3717 Latrobe Drive Suite 760
Charlotte, NC 28211

CLIENT PROJECT: 125 S. Washington Street, Wadesboro
CEI LAB CODE: A16-8532

Dear Customer:

Enclosed are asbestos analysis results for PLM Bulk samples received at our laboratory on September 29, 2016. The samples were analyzed for asbestos using polarizing light microscopy (PLM) per the EPA 600 Method.

Sample results containing >1% asbestos are considered asbestos-containing materials (ACMs) per EPA regulatory requirements. The detection limit for the EPA 600 Method is <1% asbestos by weight as determined by visual estimation.

Thank you for your business and we look forward to continuing good relations. If you have any questions, please feel free to call our office at 919-481-1413.

Kind Regards,

A handwritten signature in black ink, appearing to read "Tianbao Bai".

Tianbao Bai, Ph.D., CIH
Laboratory Director





ASBESTOS ANALYTICAL REPORT
By: Polarized Light Microscopy

Prepared for

Get The Lead Out, LLC

CLIENT PROJECT: 125 S. Washington Street, Wadesboro

CEI LAB CODE: A16-8532

TEST METHOD: EPA 600 / R93 / 116 and EPA 600 / M4-82 / 020

REPORT DATE: 09/30/16

TOTAL SAMPLES ANALYZED: 2

SAMPLES >1% ASBESTOS: 2

TEL: 866-481-1412

www.ceilabs.com



Asbestos Report Summary

By: POLARIZING LIGHT MICROSCOPY

PROJECT: 125 S. Washington Street, Wadesboro

CEI LAB CODE: A16-8532

METHOD: EPA 600 / R93 / 116 and EPA 600 / M4-82 / 020

Client ID	Layer	Lab ID	Color	Sample Description	ASBESTOS %
1	Layer 1	A2237707A	Brown,Black	Surface Mastic	None Detected
	Layer 2	A2237707A	Tan	Floor Tile	Chrysotile 10%
		A2237707B	Black	Mastic	Chrysotile 5%
2		A2237708		Sample Not Analyzed per COC	



ASBESTOS BULK ANALYSIS

By: POLARIZING LIGHT MICROSCOPY

Client: Get The Lead Out, LLC
 3717 Latrobe Drive Suite 760
 Charlotte, NC 28211

CEI Lab Code: A16-8532
Date Received: 09-29-16
Date Analyzed: 09-30-16
Date Reported: 09-30-16

Project: 125 S. Washington Street, Wadesboro

ASBESTOS BULK PLM, EPA 600 METHOD

Client ID Lab ID	Lab Description	Lab Attributes	NON-ASBESTOS COMPONENTS		ASBESTOS %
			Fibrous	Non-Fibrous	
1 Layer 1 A2237707A	Surface Mastic	Heterogeneous	75%	Mastic	None Detected
		Brown,Black	25%	Binder	
		Non-fibrous Bound			
Layer 2 A2237707A	Floor Tile	Heterogeneous	70%	Vinyl	10% Chrysotile
		Tan	20%	Calc Carb	
		Fibrous Bound			
A2237707B	Mastic	Heterogeneous Black Fibrous Bound	95%	Mastic	5% Chrysotile
2 A2237708	Sample Not Analyzed per COC				



LEGEND: Non-Anth = Non-Asbestiform Anthophyllite
 Non-Trem = Non-Asbestiform Tremolite
 Calc Carb = Calcium Carbonate

METHOD: EPA 600 / R93 / 116 and EPA 600 / M4-82 / 020

LIMIT OF DETECTION: <1% by visual estimation

REGULATORY LIMIT: >1% by weight

Due to the limitations of the EPA 600 method, nonfriable organically bound materials (NOBs) such as vinyl floor tiles can be difficult to analyze via polarized light microscopy (PLM). EPA recommends that all NOBs analyzed by PLM, and found not to contain asbestos, be further analyzed by Transmission Electron Microscopy (TEM). Please note that PLM analysis of dust and soil samples for asbestos is not covered under NVLAP accreditation.

This report relates only to the samples tested or analyzed and may not be reproduced, except in full, without written approval by CEI Labs, Inc. CEI Labs makes no warranty representation regarding the accuracy of client submitted information in preparing and presenting analytical results. Interpretation of the analytical results is the sole responsibility of the client. This report may not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government.

ANALYST: _____

Greg Ruff

APPROVED BY: _____

Tianbao Bai, Ph.D., CIH
Laboratory Director





ASBESTOS CHAIN OF CUSTODY

Lab Use Only 2
 CEI Lab Code: A16-8532
 CEI Lab ID Range: A2237707-A2237708

Company: Get the Lead Out, LLC	Office Phone: 704-376-3594
Address: 3717 Latrobe Drive, Unit 760	Cell Phone:
City, State, ZIP: Charlotte, NC 28211	Fax: 704-376-3593
Sampling Contact: Kathryn Hubicki	Email: <u>koh@gettheleadout.biz</u> <u>sandra@gettheleadout.biz</u>

Project Name: 125 S. Washington Street, Wadesboro	
Sampler Name and License Number: Kathryn Hubicki #12783	
Date Collected: 9/28/2016	State Collected: NC

Client Number 26521

Analysis Type Requested:

Asbestos Analysis <input checked="" type="checkbox"/> PLM Bulk <input type="checkbox"/> PLM 400 Point Count <input type="checkbox"/> PLM 1000 Point Count <input type="checkbox"/> PLM Gravimetric Point Count <input type="checkbox"/> PCM Air Cassette <input type="checkbox"/> Other Analysis Requested _____	TEM Analysis <input type="checkbox"/> TEM Chatfield
---	---

Turn Around Time Requested:

<input type="checkbox"/> Same Day	<input type="checkbox"/> 3 Days
<input checked="" type="checkbox"/> 1 Day	<input type="checkbox"/> 4 Days
<input type="checkbox"/> 2 Days	<input type="checkbox"/> 5 Days

Sample Number	Material Description / Location Sampled	Homogeneous Areas	Quantity	Condition	Friability (F/NF)
1	9" x 9" Vinyl Floor Tile & Mastic / First Floor	First Floor		Damaged	NF
2	9" x 9" Vinyl Floor Tile & Mastic / First Floor	First Floor		Damaged	NF

Special Instructions: Positive Stop Methodology Requested - from bottom layer up.

Relinquished By:	Date	Time	Received By:	Date	Time
<i>[Signature]</i>	9-28-16	1400	<i>[Signature]</i>	10:00	

*Samples will be retained for 30 days after analysis, unless otherwise requested.

- Accept Samples
- Reject Samples

LICENSES



North Carolina Department of Health and Human Services
Division of Public Health

Pat McCrory
Governor

Richard O. Brajer
Secretary

Daniel Staley
Acting Division Director

October 26, 2015

Kathryn Hubicki
2121 Commonwealth Ave Ste 202
Charlotte, NC 28205

Dear Ms. Hubicki:

Based upon the review of your accreditation application, the Health Hazards Control Unit (HHCU) has determined that you have fulfilled the requirements and are eligible for asbestos accreditation as a(n) MANAGEMENT PLANNER. Your assigned North Carolina accreditation number is 20990, which is reflected on your enclosed North Carolina Accreditation card. Please be sure to take this card with you to any asbestos work site where you are employed. The State requires that all persons conducting asbestos abatement or asbestos management activities be accredited and have their identification card on site.

Your North Carolina Management Planner accreditation will expire on OCTOBER 31, 2016. It is NOT the policy of the HHCU to issue renewal notices. If you wish to continue working as a(n) Management Planner after this expiration date, you must successfully complete the required training and submit a completed application to this office prior to October 31, 2016. If you should continue to perform asbestos management activities as a(n) Management Planner without a valid North Carolina accreditation, you will be in violation of State regulations and may be cited for noncompliance.

Sincerely,

Ed Norman
Program Manager
Health Hazards Control Unit



North Carolina
Asbestos Accreditation

EXPIRATION			
10-31-2016			
DOB	SEX	HT	WT
06-16-1981	F	5'5"	185
CLASS	#	EXP	
INSPECTOR	12783	10-16	
MGMT PLANNER	20990	10-16	

Kathryn Hubicki
2121 Commonwealth Ave St
Charlotte, NC 28205

109584

www.ncdhhs.gov • www.publichealth.nc.gov

Tel 919-707-5950 • Fax 919-870-4808

Location: 5505 Six Forks Road • Raleigh, NC 27609

Mailing Address: 1912 Mail Service Center • Raleigh, NC 27699-1912

An Equal Opportunity / Affirmative Action Employer

